



NOTES:

1. EXPANSION JOINT MATERIAL SHALL BE NON-EXTRUDING AND RESILIENT TYPE TO MEET AASHO SPEC. M-213.
2. ANY OVER-EXCAVATION SHALL BE REPLACED WITH GRANULAR BACKFILL COMPACTED TO 95% MAXIMUM DRY DENSITY AS DETERMINED BY ASTM D-698.

N.T.S.



STANDARDS &
SPECIFICATIONS

REVISED:

**4" MOUNTABLE
CURB, GUTTER
AND WALK**

DATE:

DRAWING NO. 500-14